



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2046164
Permit #: 01559-2025UPG
Request Rec'd: 11/19/2025
Approval Date: 11/19/2025 DS
Permit Expires: 05/19/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Speedway, LLC P.O. Box 1500 Springfield, OH 45501 Clark County Contact: Zachery Davis 937/203-7827	FACILITY - name and address where tanks are located: Speedway #6809 2139 N Mannheim Road Northlake, IL 60164 Cook County Contact: Store Manager 847/288-0133
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Premium	6,000	Currently in use	Federal
4	B-11	12,000	Currently in use	Federal
5	Gasoline - Regular	20,000	Currently in use	Federal
6	B-11	20,000	Currently in use	Federal
7	B-11	20,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket - East	Replacing - Spill Contain Device - Single Wall Spill Bucket - East
Spill Containment Device	Double Wall Spill Bucket - West	Replacing - Spill Contain Device - Single Wall Spill Bucket - West

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket - East	Replacing - Spill Contain Device - Single Wall Spill Bucket - East
Spill Containment Device	Double Wall Spill Bucket - West	Replacing - Spill Contain Device - Single Wall Spill Bucket - West

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket - East	Replacing - Spill Contain Device - Single Wall Spill Bucket - East
Spill Containment Device	Double Wall Spill Bucket - West	Replacing - Spill Contain Device - Single Wall Spill Bucket - West

Summary of Work


TANKS # 2, 4, 5, 6, and 7 = Replacing All Overspill Buckets

Special Contingencies**PERSON, FIRM OR COMPANY PERFORMING WORK:**

Anderson Pump Service, Inc.
19659 South 97th Avenue
Mokena, IL 60448

Contact Person: Ron Anderson
Phone: 708/560-5590
Email: Keith@Andersonpump.com
Contractor License # IL002275 Exp. 5/21/2026

Sincerely,



Daniel Starks