



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
[www.sfm.illinois.gov](http://www.sfm.illinois.gov)  
[SFM.DPCS@illinois.gov](mailto:SFM.DPCS@illinois.gov)

**FOR OFFICE USE ONLY**  
Facility #: 2014565  
Permit #: 01565-2025UPG  
Request Rec'd: 11/20/2025  
Approval Date: 11/21/2025 DS  
Permit Expires: 05/21/2026

### **Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

| <b>OWNER OF TANKS</b>   | <b>FACILITY</b>   |
|---|---|
| - Corporation, partnership, or other business entity:<br>MKD Properties, LLC<br>1222 Lee Street<br>Des Plaines, IL 60018<br>(None) County<br>Contact: Manjeet Kaur 708/717-9276 | - name and address where tanks are located:<br>1222 DP, Inc.<br>1222 Lee Street<br>Des Plaines, IL 60018<br>Cook County<br>Contact: Pramveer Singh 708/717-9276 |

#### **Tanks on the Permit**

| <b>Tank #</b> | <b>Product</b>     | <b>Capacity</b> | <b>Tank Status</b> | <b>Regulated Status</b> |
|---------------|--------------------|-----------------|--------------------|-------------------------|
| 5             | Gasoline - Regular | 10,000          | Currently in use   | Federal                 |
| 6             | Gasoline - Premium | 10,000          | Currently in use   | Federal                 |
| 7             | Gasoline - Regular | 10,000          | Currently in use   | Federal                 |

#### **Tank 5 Equipment**

| <b>Equipment Type</b>         | <b>Permit Equipment</b>          | <b>Action</b>   |
|-------------------------------|----------------------------------|---|
| Corrosion Protection - Piping | Sacrificial Anode Flex Connector | Removing  |
| Piping                        | Single Wall STP/Tanktop Sump     | Replacing - Piping - Single Wall STP/Tanktop Sump           |
| Spill Containment Device      | Double Wall Spill Bucket         | Replacing - Spill Contain Device - Single Wall Spill Bucket |

#### **Tank 6 Equipment**

| <b>Equipment Type</b>         | <b>Permit Equipment</b>          | <b>Action</b>   |
|-------------------------------|----------------------------------|---|
| Corrosion Protection - Piping | Sacrificial Anode Flex Connector | Removing  |
| Piping                        | Single Wall STP/Tanktop Sump     | Replacing - Piping - Single Wall STP/Tanktop Sump           |
| Spill Containment Device      | Double Wall Spill Bucket         | Replacing - Spill Contain Device - Single Wall Spill Bucket |

## Tank 7 Equipment

| Equipment Type                | Permit Equipment                 | Action  |
|-------------------------------|----------------------------------|---|
| Corrosion Protection - Piping | Sacrificial Anode Flex Connector | Removing  |
| Piping                        | Single Wall STP/Tanktop Sump     | Replacing - Piping - Single Wall STP/Tanktop Sump           |
| Spill Containment Device      | Double Wall Spill Bucket         | Replacing - Spill Contain Device - Single Wall Spill Bucket |

## Summary of Work

Replacing all 3 STP sumps and spill buckets. Removing sacrificial anodes from all 3 STP sumps only.

## Special Contingencies

### PERSON, FIRM OR COMPANY PERFORMING WORK:

|  |  |
|--|--|
| Cardinal Compliance LLC<br>415 W. Golf Rd. Unit 28M-N<br>Arlington Heights, IL 60005 | Contact Person: Chris Derro<br>Phone: 708/717-2676<br>Email: cderro@cardinalcompliance.net<br>Contractor License # IL002418 Exp. 3/21/2027 |
|--|--|

Sincerely,



Daniel Starks