



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Amended**

FOR OFFICE USE ONLY	
Facility #:	4014078
Permit #:	01378-2025CAT
Request Rec'd:	10/17/2025
Approval Date:	10/17/2025 DS
Amended Date:	11/21/2025 DS
Permit Expires:	04/17/2026

**Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Accolade Healthcare of Paxton Senior Living, LLC 450 E. Fulton Street Paxton, IL 60957 Ford County Contact: Aaron Warren 217/379-2116	<b>FACILITY</b> - name and address where tanks are located: Accolade Healthcare of Paxton Senior Living, LLC 450 Fulton Street Paxton, IL 60957 Ford County Contact: Ken White 217/379-2116
---	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	560	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Impressed Current Cathodic Protection	Replacing - Corrosion Prot - Piping - Impressed Current Cathodic Protection
Corrosion Protection - Tank	Impressed Current Cathodic Protection	Replacing - Corrosion Prot - Tank - Impressed Current Cathodic Protection

**NACE Certified Designer**  
**NACE Certified Designer Number**  
**Method of Integrity Assessment of Tanks**

**Special Contingencies**

**Amendment Reason:**

Good morning. We would like to have the option to complete the installation of (1 to 2) anodes and or anode wiring if needed to complete the system.

**Summary of Work**

This is a like for like installation of a replacement rectifier only. The existing rectifier was removed with the old generator and not replaced when the new generator was set. The new rectifier is the same as what was removed. Once installed start up and testing will be completed. We will connect the same mounting bracket, same AC wiring connected to the old rectifier, use of the same anode connections will be completed. If the anodes do not test or wiring is not intact we will install the new wiring as needed or the installation of (1 to 2) anodes, connection to the new rectifier and required testing. The tank, the piping and all of the tank equipment will remain the same.

**PERSON, FIRM OR COMPANY PERFORMING WORK:**

Bolin Enterprises, Inc.  
506 North East 15th Street PO Box 70  
Casey, IL 62420

Contact Person: Scott Justice  
Phone: 217/251-6094  
Email: scott.justice@bolininc.com  
Contractor License # IL002333 Exp. 10/10/2026

Sincerely,

  
\_\_\_\_\_

Daniel Starks