



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 217/785-1020  
 www.sfm.illinois.gov  
 SFM.DPCS@illinois.gov

<b>FOR OFFICE USE ONLY</b>	
Facility #:	2027427
Permit #:	01585-2025CAT
Request Rec'd:	11/24/2025
Approval Date:	11/24/2025 DS
Permit Expires:	05/27/2026

**Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Casey's Retail Company 3305 SE Delaware Ave. P.O. Box 3004 Ankeny, IA 50021 Contact: Lee Lytle 515/446-6231	<b>FACILITY</b> - name and address where tanks are located: Bucky's Express #6431 2580 Skokie Valley Road Highland Park, IL 60035 Lake County Contact: Riccardo Naranjos 515/416-6238
--	---

**Tanks on the Permit For Piping Only**

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Premium	12,000	Currently in use	Federal
3	Gasoline - Regular	12,000	Currently in use	Federal

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - Disp 3/4	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - Disp 3/4

**Tank 3 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - Disp 5/6	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - Disp 5/6

**NACE Certified Designer**  
**NACE Certified Designer Number**  
**Method of Integrity Assessment of Tanks**

**Special Contingencies**

**Summary of Work**

Replace (2) sacrificial anodes. Install (1) anode into dispenser 3/4 and (1) anode into dispenser 5/6

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Protanic, LLC 658 North Progress Drive PO Box 80265 Saukville, WI 53080	Contact Person: Kylie Krombach Phone: 262/268-1150 Email: danc@protanicinc.com Contractor License # IL1413 Exp. 9/26/2026

Sincerely,

*Daniel J. Starks*

Daniel Starks