



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Revised**

**FOR OFFICE USE ONLY**  
Facility #: 2001722  
Permit #: 01251-2025INS  
Request Rec'd: 09/23/2025  
Approval Date: 09/23/2025 DS  
Revision Date: 10/09/2025 DS  
Permit Expires: 03/24/2026

**Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted. The tank owner must submit a Notification for Underground Storage Tanks form prior to the scheduling of the final schedule at: <https://webapps.sfm.illinois.gov/USTPortal/NotificationForm>.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Indian Head Transit Company Inc. 9901 S. Sayre Avenue Chicago Ridge, IL 60415 Cook County Contact: Todd Mancuso 708/560-9840	<b>FACILITY</b> - name and address where tanks are located: Frontier Coach, Inc. 9901 S. Sayre Avenue Chicago Ridge, IL 60415 Cook County Contact: Manny Valdez 708/425-3075
--	--

**Tanks on the Permit**

<b>Tank #</b>	<b>Product</b>	<b>Capacity</b>	<b>Tank Status</b>	<b>Regulated Status</b>
3	Gasoline - Regular	10,000	Installed/Not in Use	Federal

**Tank 3 Equipment**

<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Corrosion Protection - Piping	Fiberglass Non-Corrosive	New
Corrosion Protection - Tank	Composite Non-Corrosive	New
Leak Detection - Piping	European with No Test Req Suction	New
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 300c	New
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	New
Overfill Prevention Device	Overfill Drop Tube Valve	New
Piping	Ball Valves	New
Piping	Fiberglass Double Wall Ameron Dualoy 3000/LCX	New
Piping	Fiberglass Single Wall Piping Vent	New
Piping	Flex Connector Steel	New
Piping	Other Steel Riser	New
Piping	Single Wall STP/Tanktop Sump	New
Spill Containment Device	Double Wall Spill Bucket	New
Tank	Composite Double Wall Modern Welding Glasteel II	New

**Dispensers on the Permit**

<b>Dispenser</b>	<b>Action</b>
1/2	Replacing - 1/2

## Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump

### General Requirements

USTs shall be installed to safeguard against movement by anchoring in accordance with manufacturer's instructions. There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

### Summary of Work

installation new double walled 10,000 gallon modern welding glassteel 2 tank

Installing single wall tank and dispenser sumps

Installing double wall LCX product piping

Installing single wall fiberglass vent piping with galvanized steel riser to 12'

Installing Veeder Root TLS300C with interstitial monitoring (this is being re-used from the tank that is being replaced)

Install European suction piping (No sensor, but permit application forces that one is put in)

Re-using existing dispenser

### Special Contingencies

**NOTES: Vents must meet section 175.440 of our rules. Dispenser must be a full 10' to all buildings and property lines.**

### Revision Reason:

Changed product to gasoline and changed ownership

#### PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group  
2422 Center Street  
Rockford, IL 61108

Contact Person: Robert Stenstrom  
Phone: 630/878-6354  
Email: jasonre@rstenstrom.com  
Contractor License # IL1890 Exp. 4/12/2026

Sincerely,



Daniel Starks

### For Office Use Only

## Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Required in Single Wall UDC Sump	Removing
Leak Detection - Piping	Piping Sump Sensors Not Regulated in Single Wall UDC Sump	New