



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2027516
Permit #: 01605-2025UPG
Request Rec'd: 12/01/2025
Approval Date: 12/01/2025 DS
Permit Expires: 06/02/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity:	FACILITY - name and address where tanks are located:
Eastkuttu, Inc. 435 W. Roosevelt Road Lombard, IL 60148 Du Page County Contact: Steve Chacko 773/671-9854	Eastkuttu, Inc. 435 W. Roosevelt Road Lombard, IL 60148 Du Page County Contact: Mini Mathai 630/268-1552

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	10,000	Currently in use	Federal
2	Gasoline - Premium	10,000	Currently in use	Federal
3	Gasoline - Regular	10,000	Currently in use	Federal
4	Gasoline - Regular	10,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	New
Piping	Shear Valves	New

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	New
Piping	Shear Valves	New

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	New
Piping	Shear Valves	New

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	New
Piping	Shear Valves	New

Dispensers on the Permit

Dispenser	Action
9/10	Sump / Sensors Changing

Dispenser 9/10 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump

Summary of Work

The shear valves are broken in Dispenser 9/10 because of impact and need to install UDC as the site don't have containmnet

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
America Petropump Services LLC d/b/a Ampsco Services 4075 Fox Valley Center Dr., Unit 9 Aurora, IL 60504	Contact Person: Ravindra Pennmatsa Phone: 312/286-6722 Email: ravi@ampsco.net Contractor License # IL002420 Exp. 5/22/2027

Sincerely,



Daniel Starks