



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2009298
Permit #: 01607-2025CAT
Request Rec'd: 12/01/2025
Approval Date: 12/02/2025 DS
Permit Expires: 06/02/2026

Permit for INSTALLATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS	FACILITY
- Corporation, partnership, or other business entity: Anabi Real Estate Development, LLC, Designated Series D3 1450 N, Benson Ave., Suite A Upland, CA 91786 (None) County Contact: Denise Soto 909/394-4728	- name and address where tanks are located: Rawa Midwest Convenience, Inc. 8716 Ogden Avenue Lyons, IL 60534 Cook County Contact: Jenelle Stewart 708/890-8971

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Gasoline - Regular	12,000	Currently in use	Federal
6	B-11	12,000	Currently in use	Federal
7	Gasoline - Premium	12,000	Currently in use	Federal

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Tank - Sacrificial Anode Cathodic Protection with Dielectric Coating Bonding additional sacrificial anodes to existing STI P3 tank

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Tank - Sacrificial Anode Cathodic Protection with Dielectric Coating Bonding additional sacrificial anodes to existing STI P3 tank

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Tank - Sacrificial Anode Cathodic Protection with Dielectric Coating Bonding additional sacrificial anodes to existing STI P3 tank

NACE Certified Designer

NACE Certified Designer Number

Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

Install two 20 pound high potential magnesium anodes on each of the tanks (3) at 10' spacing, 1' below tank bottom, through a mini test station and bonding to the tank top on the midgrade and through the PP2 wires on the unleaded and premium.

PERSON, FIRM OR COMPANY PERFORMING WORK:

Tanknology
880 Church Road
Elgin, IL 60123

Contact Person: Linda Przydzial
Phone: 512/380-7117
Email: dhollander@tanknology.com
Contractor License # IL2089 Exp. 3/4/2026

Sincerely,



Daniel Starks