



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 4006612
Permit #: 01608-2025UPG
Request Rec'd: 12/02/2025
Approval Date: 12/02/2025 DS
Permit Expires: 06/02/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| OWNER OF TANKS - Corporation, partnership, or other business entity: Charles H. Winks 1902 W Market Bloomington, IL 61701 McLean County Contact: Lisa Trunnell 309/287-3909 | FACILITY - name and address where tanks are located: Winks Shell, LLC 1902 W Market Bloomington, IL 61701 McLean County Contact: Lisa Trunnell 309/828-0902 |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|---------------|----------------------|-----------------|--------------------|-------------------------|
| 1 | Gasoline - Mid-grade | 10,000 | Currently in use | Federal |
| 2 | Gasoline - Regular | 10,000 | Currently in use | Federal |
| 3 | Gasoline - Premium | 10,000 | Currently in use | Federal |

Tank 1 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--------------------------------------------|-------------------------------------------------------------------------------|
| Leak Detection - Piping | Mechanical Pressurized Line Leak Detection | Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection |

Tank 2 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--------------------------------------------|-------------------------------------------------------------------------------|
| Leak Detection - Piping | Mechanical Pressurized Line Leak Detection | Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection |

Tank 3 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--------------------------------------------|-------------------------------------------------------------------------------|
| Leak Detection - Piping | Mechanical Pressurized Line Leak Detection | Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection |

Summary of Work

Replacing existing Incon electronic line leak detectors with Red Jacket FX1V mechanical line leak detectors and performing annual line and leak detector testing.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Total Petroleum Service Company
2421 Washington Road
Washington, IL 61571

Contact Person: Cheri McCoy
Phone: 309/694-8224
Email: Tom.Oltman@TotalPetroleum.net
Contractor License # IL1079 Exp. 2/8/2026

Sincerely,

Daniel G. Starks

Daniel Starks