



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
[www.sfm.illinois.gov](http://www.sfm.illinois.gov)  
[SFM.DPCS@illinois.gov](mailto:SFM.DPCS@illinois.gov)

**FOR OFFICE USE ONLY**  
Facility #: 2000783  
Permit #: 01610-2025UPG  
Request Rec'd: 12/02/2025  
Approval Date: 12/02/2025 DS  
Permit Expires: 06/02/2026

### **Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b>	<b>FACILITY</b>
- Corporation, partnership, or other business entity: 7-Eleven, Inc. 3200 Hackberry Road - Gas Compliance Irving, TX 75063 (None) County Contact: Zachary Davis 937/203-7827	- name and address where tanks are located: 7-Eleven Store #30126 900 Arlington Heights Road Elk Grove Village, IL 60007 Cook County Contact: Cesar Franco 847/608-1136

#### **Tanks on the Permit**

<b>Tank #</b>	<b>Product</b>	<b>Capacity</b>	<b>Tank Status</b>	<b>Regulated Status</b>
5	Gasoline - Regular	15,000	Currently in use	Federal

#### **Tank 5 Equipment**

<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Other Fiberglass Riser - Vapor Riser	New
Piping	Other Fiberglass Riser - Fill Riser	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Double Wall Spill Bucket

#### **Summary of Work**

Tank# 5 Regular = Installing New Fill and Vapor Risers, Replacing Overspill bucket and Overfill drop tube

#### **Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 708/560-5590 Email: <a href="mailto:Keith@Andersonpump.com">Keith@Andersonpump.com</a> Contractor License # IL002275 Exp. 5/21/2026

Sincerely,

Daniel Starks