



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY
Facility #: 7021575
Permit #: 01593-2025UPG
Request Rec'd: 11/20/2025
Approval Date: 11/25/2025 DS
Amended Date: 12/04/2025 DS
Permit Expires: 05/27/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS	FACILITY
- Corporation, partnership, or other business entity: Veera Ashvi, LLC 500 W. 10th Street Metropolis, IL 62960 Massac County Contact: Julie Patel 618/634-9630	- name and address where tanks are located: Pickup Mart 17753 IL 37 Karnak, IL 62956 Pulaski County Contact: Beena Patel 618/634-9630

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Gasoline - Regular	10,000	Currently in use	Federal
6	Diesel Fuel	4,000	Currently in use	Federal

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Fiberglass Non-Corrosive	Removing
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Piping	Flexible Double Wall OPW Flexworks	Replacing - Piping - Fiberglass Single Wall Piping
Piping	Polyethylene Chase	New
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Fiberglass Non-Corrosive	Removing
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - Dispenser 6	Removing
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Piping	Flexible Double Wall OPW Flexworks	Replacing - Piping - Fiberglass Single Wall Piping
Piping	Polyethylene Chase	New
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Dispensers on the Permit

Dispenser	Action
1/2	Replacing - 1/2
3/4	Replacing - 4/5
3	Removing
6	Removing

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

Dispenser 3 Equipment

Equipment Type	Permit Equipment	Action

Dispenser 6 Equipment

Equipment Type	Permit Equipment	Action

Summary of Work

- Remove and dispose of old dispensers.
- Saw cut and bust out existing dispenser islands.
- Furnish and install (2) fiberglass dispenser sumps.
- Re-route existing single wall FRP piping and conduits into new dispenser sumps.
- Pull in new dispenser power wire and low voltage wiring for card readers.
- Backfill and repour dispenser island using no island forms. (dispensers will sit on sloped concrete island)
- Furnish and install (1) Gilbarco Encore 700 single grade, dual side MPD for unleaded with Flex pay 6, GCM and valance.
- Furnish and install (1) Gilbarco Encore 700 dual grade, dual side MPD for unleaded and diesel with Flex pay 6, GCM and valance.
- Furnish and install all new hanging hardware.
- Furnish and install single Gilbarco Passport.
- Start-up and calibrate dispensers and Passport.
- Perform precision line test.

Saw cut and remove concrete over conduit/piping trench.

Provide Vac truck to remove back fill in existing conduit trench. (conduits are directly above product lines)

Remove existing single wall piping and tank sumps. (Includes removal permit, 20 sample, site assessment report)

Furnish and install (2) fiberglass tanks sumps.

Furnish and install (2) 1.5 HP motors and leak detectors.

Furnish and install all conduit boots and product boots to complete the job.

Furnish and install 350' of OPW double wall flex piping for unleaded and diesel.

Furnish and install (2) red Jacket control boxes

Furnish and install 700' on conduit to dispensers, canopy light, price sign, tank motors and tank probes.

Back fill and repour concrete.

Special Contingencies

NOTE: Dispensers must be at least 10' from all buildings and property lines

Amendment Reason:

Replacing all single wall piping with OPW double wall flex works piping and replacing STP sumps with fiberglass sumps.

PERSON, FIRM OR COMPANY PERFORMING WORK:

Hinderliter Construction & Maint., Inc. 3601 North St. Joseph Avenue Evansville, IN 47720	Contact Person: Mark Hinderliter Phone: 812/425-4137 Email: ehinderliter@hci4.com Contractor License # IL646 Exp. 7/3/2026
---	---

Sincerely,



Daniel Starks

For Office Use Only

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Required in Single Wall STP/Tanktop Sump	Removing

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Required in Single Wall STP/Tanktop Sump	Removing

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Required in Single Wall UDC Sump	Removing

Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
----------------	------------------	--------

Dispenser 3 Equipment

Equipment Type	Permit Equipment	Action
----------------	------------------	--------

Dispenser 6 Equipment

Equipment Type	Permit Equipment	Action
----------------	------------------	--------