



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 3007443
Permit #: 01635-2025UPG
Request Rec'd: 12/08/2025
Approval Date: 12/08/2025 DS
Permit Expires: 06/09/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|---|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Mac's Convenience Stores, LLC 1100 Situs Court, Suite 100 Raleigh, NC 27606 (None) County Contact: Michele Alvarado 773/456-5280 | FACILITY - name and address where tanks are located: Circle K #4701444 1010 N. Main Street Monmouth, IL 61462 Warren County Contact: Bessie Short 984/389-1765 |
|--|---|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 4 | Gasoline - Premium | 10,000 | Currently in use | Federal |

Tank 4 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|------------------|--------|
| Piping | Ball Valves | New |

Summary of Work

REPLACING 1.5 HP RED JACKET STP MOTOR

Special Contingencies

NOTE: A sump must be installed if not already existing

| | |
|--|---|
| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| Neumayer Equipment Company, Inc. 5060 Arsenal Street St. Louis, MO 63139 | Contact Person: Jimmy Spiros Phone: 314/772-4501 Email: testing@neumayerequipment.com Contractor License # IL1502 Exp. 3/26/2026 |

Sincerely,

Daniel Starks