



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2038892
Permit #: 01636-2025UPG
Request Rec'd: 12/08/2025
Approval Date: 12/09/2025 DS
Permit Expires: 06/09/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS	FACILITY
- Corporation, partnership, or other business entity: 123 Halsted LLC 12304 S. Halsted St. Calumet Park, IL 60827 Cook County Contact: Ali Alraiwe 773/226-1031	- name and address where tanks are located: 123 Halsted LLC 12304 S. Halsted St. Calumet Park, IL 60827 Cook County Contact: Ali Alraiwe 773/226-1031

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Premium	8,000	Currently in use	Federal
2	Gasoline - Regular	12,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Overfill Prevention Device	Overfill Drop Tube Valve	New
Piping	Ball Valves	New
Piping	Fiberglass Single Wall Piping A.O. Smith	New
Piping	Flex Connector Steel	New
Piping	Other Steel Riser	New
Piping	Other Submersible Pump	New
Piping	Single Wall STP/Tanktop Sump	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

Another contractor with active permit has installed STP sump on premium tank, but as per owner he is not cooperating and is not finalizing the final inspection with fire marshall. He is not responsive and as per owner they waited for him more than 2 months and site is down on premium because of him. We are getting permit for STP sump on TANK 1 premium just to schedule final inspection with fire marshall. Rest sump has already been installed, line tightness test has already been submitted. we will just do hydrostatic test on sump and schedule final inspection with fire marshall. Replacing spill buckets on both tanks with Double wall spill buckets and Installing overfill droptubes.

Special Contingencies**PERSON, FIRM OR COMPANY PERFORMING WORK:**

American Petroleum Solutions LLC
7143 Polo Place
Loves Park, IL 61111

Contact Person: Haibat Khan
Phone: 909/312-9449
Email: apetro.office@gmail.com
Contractor License # IL002454 Exp. 5/21/2026

Sincerely,



Daniel Starks

For Office Use Only**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Not Installed STP/Tanktop Sump	Removing