



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2047967
Permit #: 01644-2025ABN
Request Rec'd: 12/09/2025
Approval Date: 12/11/2025 DS
Permit Expires: 06/11/2026

Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: East Maine School District 63 10150 Dee Road Des Plaines, IL 60016 (None) County Contact: Rick Kunz 847/299-1900	FACILITY - name and address where tanks are located: Mark Twain School 9401 N Hamlin Ave Niles, IL 60016 Cook County Contact: Anthony Bersani 847/493-8404
--	---

Tanks on the Permit

* A combination of inert fill material is not allowed. The listed inert fill material is only allowed to fill the abandoned tank.

Tank #	Capacity	Product	Fill Material *
1	10,000	#2 Fuel Oil	Inert material mixed with portland cement

Explanation of Waiver for Abandonment

The UST is located under the schools ac chillers and back up generator. There is also a gas line running over the top of the UST.

The UST and piping will be abandoned in place.

CONTAMINATED SITE!

IEMA Number
2025-0930

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Orivne, Inc. PO Box 46249 Chicago, IL 606460249	Contact Person: Mike Leyden Phone: 312/656-2009 Email: mleyden@orivne.us Contractor License # IL002408 Exp. 5/1/2027

Sincerely,

Daniel Starks