



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	4005670
Permit #:	01652-2025UPG
Request Rec'd:	12/12/2025
Approval Date:	12/12/2025 DS
Permit Expires:	12/23/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Crescent Street Center, LLC 1255 Lakes Parkway, Suite 180 Lawrenceville, GA 33043 (None) County Contact: Brad Hall 770/338-2620	FACILITY - name and address where tanks are located: K & H Truck Plaza 1043 S. Crescent Gilman, IL 60938 Iroquois County Contact: Jermiah Jones 870/866-1234
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Gasoline - Premium	10,000	Currently in use	Federal

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Piping	Ball Valves	New

Summary of Work

US TANK failed the premium line tightness test for a leaking ball valve in the stp sump. Need to replace the Ball valve on the Premium line in the STP sump.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
JF Acquisition, LLC d/b/a Jones & Frank 100 Perimeter Park Drive Suite H Morrisville, NC 275609203	Contact Person: Kevin Whritenour Phone: 618/306-5098 Email: scot.russell@jfpetrogroup.com Contractor License # IL002422 Exp. 5/14/2026

Sincerely,

Daniel Starks