



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
[www.sfm.illinois.gov](http://www.sfm.illinois.gov)  
[SFM.DPCS@illinois.gov](mailto:SFM.DPCS@illinois.gov)  
**Revised/Amended**

**FOR OFFICE USE ONLY**  
Facility #: 7042092  
Permit #: 01620-2025UPG  
Request Rec'd: 12/04/2025  
Approval Date: 12/04/2025 DS  
Amended Date: 12/16/2025 DS  
Revision Date: 12/17/2025 DS  
Permit Expires: 06/04/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b>	<b>FACILITY</b>
- Corporation, partnership, or other business entity: Love's Travel Stops & Country Stores, Inc. 10601 N. Penn P.O. Box 26210 Oklahoma City, OK 73120 Contact: Kyle Collins 405/834-0311	- name and address where tanks are located: Love's Travel Stop #318 202 North Ave. Ina, IL 62846 Jefferson County Contact: Lance Canteloupe 405/302-6640

**Tanks on the Permit**

<b>Tank #</b>	<b>Product</b>	<b>Capacity</b>	<b>Tank Status</b>	<b>Regulated Status</b>
4	Gasoline - Regular	8,000	Currently in use	Federal
5	Gasoline - Premium	12,000	Currently in use	Federal
6	Gasoline - Regular	20,000	Currently in use	Federal

**Tank 4 Equipment**

<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Replacing - Leak Detect - Piping - Sump Sensor
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Siphon Bar
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors With Monitor
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Ball Valves	New
Piping	Blending Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New
Piping	Flex Connector Steel	New
Piping	Other Steel Riser	New
Piping	Other Submersible Pump	New

## Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Replacing - Leak Detect - Piping - Sump Sensor
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors With Monitor
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	New

## Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Replacing - Leak Detect - Piping - Sump Sensor
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors With Monitor
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve

## Summary of Work

Sawcut and break concrete over Siphon Unleaded, Unleaded, and Premium tanks  
 Remove concrete and vac gravel to expose piping  
 Install dual meter sump, dual meter assembly, and sump sensor  
 Reroute Unleaded siphon line in to new dual meter sump  
 Run new line from dual meter sump to Premium STP sump  
 Remove siphon suction leg and re-install in Premium STP sump  
 Install new sub pump in Siphon Unleaded sump for E98  
 Test all piping and water test sums  
 Once inspections are passed, backfill trench and tank area  
 Set manholes and prep for concrete.  
 Pour concrete over tanks  
 Install customer supplied TMS panel next to TLS per plans  
 Transfer bio controls to the TMS panel  
 Pull wire and make connections  
 Install new drop tube in E98 tank  
 Startup and test system  
 Adding a remote fill for Premium Tank 5

## Special Contingencies

**NOTE: Remove fill must meet section 175.445 of our rules**

### Amendment Reason:

We are adding a remote fill for Premium Tank 5

### Amendment Reason:

We are adding a remote fill for Premium Tank 5

### Revision Reason:

Added tanks 4 & 6 back onto permit after they were removed during the amendment.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Illinois Oil Marketing Equipment, Inc. 850 Brenkman Drive Pekin, IL 61554	Contact Person: Bryan Estes Phone: 309/678-8061 Email: pcarrabbia@iome.com Contractor License # IL1293 Exp. 2/4/2026

Sincerely,

Daniel G. Starks

Daniel Starks