



**City of Chicago**  
**Department of Public Health**  
 333 South State Street, Room 200  
 Chicago, IL 60604  
 312/745-3162  
 www.sfm.illinois.gov  
 SFM.DPCS@illinois.gov

<b>FOR OFFICE USE ONLY</b>	
Facility #:	2047970
Permit #:	01669-2025REM
Request Rec'd:	12/17/2025
Approval Date:	12/18/2025 SK
Permit Expires:	06/18/2026

**Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176 . The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>OWNER OF TANKS</b>          - Corporation, partnership, or other business entity:          Public Building Commission of Chicago          50 W. Washington St., Room 200          Chicago, IL 60602          Contact: Ray Giderof 312/744-3090</p>	<p><b>FACILITY</b>          - name and address where tanks are located:          Canty Elementary          3740 N. Panama Ave          Chicago, IL 60634          Cook County          Contact: Richard Schleyer 773/251-7074</p>
--	---

**Tanks on the Permit**

Tank #	Capacity	Product	Last Used Date
1	5,000	Heating Oil	12/31/1973

**Summary of Work**

Removal of one 5000 gallon vaulted tank

**Special Contingencies**

The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
RW Collins Company 7225 West 66th Street Chicago, IL 60638	Contact Person: Lisa Kruse Phone: 779/301-5966 Email: slucero@rwcollins.com Contractor License # IL772 Exp. 2/9/2026

Sincerely,

Sean Keane