



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov
Extended

FOR OFFICE USE ONLY	
Facility #:	2022861
Permit #:	00886-2025UPG
Request Rec'd:	07/11/2025
Approval Date:	07/11/2025 DS
Extension Date:	12/30/2025
Permit Expires:	07/14/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE EXTENSION DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Graham Enterprise, Inc. 750 Bunker Court Vernon Hills, IL 60061 Lake County Contact: Raymond Kirchner 847/837-0777	FACILITY - name and address where tanks are located: Wilmette BP SS#285 840 Skokie Boulevard Wilmette, IL 60091 Cook County Contact: Margarita Buruiana 847/251-4321
------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
8	Gasoline - Regular	12,000	Currently in use	Federal
9	Gasoline - Premium	12,000	Currently in use	Federal
10	Gasoline - Regular	12,000	Currently in use	Federal
11	Diesel Fuel	6,000	Currently in use	Federal

Tank 8 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing
Leak Detection - Piping	Siphon Bar	Removing
Piping	Flex Connector Steel	Replacing - Piping - Flex Connector Steel
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
↳ Leak Detection - Piping	Sump Sensor	Reusing Existing

Tank 9 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - DISP 5/6	Removing
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - DISP 5/6	Removing
Piping	Flex Connector Steel	Replacing - Piping - Flex Connector Steel
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
↳ Leak Detection - Piping	Sump Sensor	Reusing Existing

Tank 10 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - DISP 9/10	Removing
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - DISP 9/10	Removing
Leak Detection - Piping	Siphon Bar	Removing
Piping	Flex Connector Steel	Replacing - Piping - Flex Connector Steel
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
↳ Leak Detection - Piping	Sump Sensor	Reusing Existing

Tank 11 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - DISP 11/12	Removing
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - DISP 11/12	Removing
Piping	Flex Connector Steel	Replacing - Piping - Flex Connector Steel
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
↳ Leak Detection - Piping	Sump Sensor	Reusing Existing

Dispensers on the Permit

Dispenser	Action
1/2	Sump / Sensors Changing
3/4	Sump / Sensors Changing
5/6	Sump / Sensors Changing
7/8	Sump / Sensors Changing
9/10	Sump / Sensors Changing
11/12	Sump / Sensors Changing

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump

Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump

Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump

Dispenser 7/8 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump

Dispenser 9/10 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump

Dispenser 11/12 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump


Summary of Work

We will be replacing the existing poly STP Sumps with SWFRP STP Sumps on the (4) existing tanks. We will be installing (6) SWFRP UDC's / Dispenser Sumps at the (6) dispenser island locations. Revisions to the existing DWFRP piping only as needed to facilitate the install of new sumps.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Performance Tank, Inc. 730 Creel Drive Wood Dale, IL 60191	Contact Person: Tim Berg Phone: 847/612-6551 Email: tberg@perftank.com Contractor License # IL881 Exp. 12/8/2026

Sincerely,



Daniel Starks