



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
[www.sfm.illinois.gov](http://www.sfm.illinois.gov)  
[SFM.DPCS@illinois.gov](mailto:SFM.DPCS@illinois.gov)

**FOR OFFICE USE ONLY**  
Facility #: 1046211  
Permit #: 01697-2025UPG  
Request Rec'd: 12/31/2025  
Approval Date: 12/31/2025 DS  
Permit Expires: 06/30/2026

### **Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity:	<b>FACILITY</b> - name and address where tanks are located:
Speedway, LLC P.O. Box 1500 Springfield, OH 45501 Clark County  Contact: Zachary Davis 937/203-7827	Speedway #3995 2091 Crystal Parkway Belvidere, IL 61008 Boone County  Contact: Danielle Ladner 815/547-8262

#### **Tanks on the Permit**

<b>Tank #</b>	<b>Product</b>	<b>Capacity</b>	<b>Tank Status</b>	<b>Regulated Status</b>
2	B-11	20,000	Currently in use	Federal
3	B-11	20,000	Currently in use	Federal
4	Gasoline - Regular	20,000	Currently in use	Federal
5	B-11	12,000	Currently in use	Federal
6	E85	6,000	Currently in use	Federal

#### **Tank 2 Equipment**

<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Overfill Prevention Device	Overfill Drop Tube Valve - North	Replacing - Overfill Prev Device - Overfill Drop Tube Valve - North
Overfill Prevention Device	Overfill Drop Tube Valve - South	Replacing - Overfill Prev Device - Overfill Drop Tube Valve - South
Spill Containment Device	Double Wall Spill Bucket - South	Replacing - Spill Contain Device - Double Wall Spill Bucket - South
Spill Containment Device	Double Wall Spill Bucket - North	Replacing - Spill Contain Device - Single Wall Spill Bucket - North

### Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve - North	Replacing - Overfill Prev Device - Overfill Drop Tube Valve - North
Overfill Prevention Device	Overfill Drop Tube Valve - South	Replacing - Overfill Prev Device - Overfill Drop Tube Valve - South
Spill Containment Device	Double Wall Spill Bucket - South	Replacing - Spill Contain Device - Double Wall Spill Bucket - South
Spill Containment Device	Double Wall Spill Bucket - North	Replacing - Spill Contain Device - Single Wall Spill Bucket - North

### Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve - North	Replacing - Overfill Prev Device - Overfill Drop Tube Valve - North
Overfill Prevention Device	Overfill Drop Tube Valve - South	Replacing - Overfill Prev Device - Overfill Drop Tube Valve - South
Piping	Other Fiberglass Riser - South Fill	New
Piping	Other Fiberglass Riser - North Fill	New
Spill Containment Device	Double Wall Spill Bucket - South	Replacing - Spill Contain Device - Double Wall Spill Bucket - South
Spill Containment Device	Double Wall Spill Bucket - North	Replacing - Spill Contain Device - Single Wall Spill Bucket - North

### Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

### Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Other Fiberglass Riser	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

### Summary of Work

E85 Tank = Installing (1) new fill riser, Replacing Overspill bucket and Overfill drop tube. Regular Tank = Installing (2) new fill risers, Replacing (2) Overspill buckets and (2) Overfill drop tubes. (3) Diesel Tanks = Replacing (5) Overspill buckets and (5) Overfill drop tubes.

### Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 708/560-5590 Email: Keith@Andersonpump.com Contractor License # IL002275 Exp. 5/21/2026

Sincerely,



Daniel Starks