



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
[www.sfm.illinois.gov](http://www.sfm.illinois.gov)  
[SFM.DPCS@illinois.gov](mailto:SFM.DPCS@illinois.gov)

**FOR OFFICE USE ONLY**  
Facility #: 2009009  
Permit #: 01699-2025UPG  
Request Rec'd: 12/31/2025  
Approval Date: 12/31/2025 DS  
Permit Expires: 06/30/2026

### **Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b>	<b>FACILITY</b>
- Corporation, partnership, or other business entity: Esquire Petroleum, LLC 980 N. Michigan Ave., #1400 Chicago, IL 60611 Cook County Contact: Carmella Payne 262/797-0970	- name and address where tanks are located: Mobil Oil O5-BDF 1401 East 159th Street Calumet City, IL 60409 Cook County Contact: Station Mgr 708/862-2255

#### **Tanks on the Permit**

<b>Tank #</b>	<b>Product</b>	<b>Capacity</b>	<b>Tank Status</b>	<b>Regulated Status</b>
1	Gasoline - Regular	10,000	Currently in use	Federal

#### **Tank 1 Equipment**

<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Other Non-vented check valve

#### **Summary of Work**

Removing manifold under dispenser, replacing mechanical check valve with electronic leak detector.

#### **Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: DJ White Phone: 708/474-3344 Email: <a href="mailto:dj.white@bkequip.com">dj.white@bkequip.com</a> Contractor License # IL1207 Exp. 2/14/2026

Sincerely,

Daniel Starks