



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Extended

FOR OFFICE USE ONLY	
Facility #:	2032134
Permit #:	00855-2025UPG
Request Rec'd:	07/08/2025
Approval Date:	07/08/2025 DS
Extension Date:	01/02/2026
Permit Expires:	07/08/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE EXTENSION DATE.

OWNER OF TANKS	FACILITY
- Corporation, partnership, or other business entity: Schaumburg Park District 235 East Beech Drive Schaumburg, IL 60193 Cook County Contact: David Johnson 847/985-2115	- name and address where tanks are located: Schaumburg Park Dist 601 Morse Ave Schaumburg, IL 60193 Cook County Contact: Sal Guagliardo 847/985-2115

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	6,000	Currently in use	Federal
2	Diesel Fuel	4,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Fiberglass Non-Corrosive	Replacing - Corrosion Prot - Piping - Fiberglass Non-Corrosive
Piping	Fiberglass Double Wall	Replacing - Piping - Fiberglass Double Wall
Piping	Shear Valves	New

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Fiberglass Non-Corrosive	Replacing - Corrosion Prot - Piping - Fiberglass Non-Corrosive
Piping	Fiberglass Double Wall	Replacing - Piping - Fiberglass Double Wall
Piping	Shear Valves	New

Dispensers on the Permit

Dispenser	Action
dsl	Sump / Sensors Changing
unl	Sump / Sensors Changing

Dispenser dsl Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New

Dispenser unl Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New

Summary of Work

Removing:

Exiting canopy.

Island.

(2) dispensers.

Installing:

New canopy.

New under dispenser containment.

(2) new dispensers for gas and diesel.

The existing pipe will be cut back to allow for the install of the dispenser containemnt and then replaced. Total length approximately 3-4 feet.

(1) new island form with crash protection

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Crowne Industries, Ltd. 325 W. Highland Avenue Elgin, IL 60123	Contact Person: Robert Sumoski Phone: 630/201-4967 Email: bob@crownetank.com Contractor License # IL002345 Exp. 5/16/2026
--	--

Sincerely,



Daniel Starks

For Office Use Only

Dispenser dsl Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing
↳ Leak Detection - Piping	Piping Sump Sensors Not Regulated	New

Dispenser unl Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing
↳ Leak Detection - Piping	Piping Sump Sensors Not Regulated	New