



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2008602
Permit #: 00001-2026LIN
Request Rec'd: 12/26/2025
Approval Date: 01/04/2026 SK
Permit Expires: 07/07/2026

Permit for INSPECTION OF INTERIOR LINING of Underground Storage Tank(s) for Petroleum and Hazardous Substances

Permission to inspect existing interior lining of underground storage tank(s) is hereby granted. Such inspections of interior lining must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. **THIS PERMIT IS FOR THE INTERIOR INSPECTION OF THE EXISTING LINING ONLY! NO REPAIRING, UPGRADING, OR INTERIOR LINING IS AUTHORIZED WITH THIS PERMIT.**

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS	FACILITY
- Corporation, partnership, or other business entity: RM Lucas Company, An Illinois Corporation 3211 South Wood Street Chicago, IL 60608 Cook County Contact: Larry Burkett 773/523-4300	- name and address where tanks are located: R M Lucas Company 3211 South Wood Street Chicago, IL 60608 Cook County Contact: Rob Barry 773/523-4300

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status	Manway
2	Mineral Spirits	3,000	Currently in use	Federal	Existing
4	Mineral Spirits	3,000	Currently in use	Federal	Existing

Summary of Work

Cut, bust and remove concrete. Excavate area over tanks. Purge, clean, re-inspect and re-certify the internal lining of the following tanks in accordance with State of Illinois 175 regulations and NLPA-631 requirements. Backfill and recover with new reinforced concrete.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Armor Shield of Wisconsin 3965 Hillside Road Slinger, WI 53086	Contact Person: Clayton Bennett Phone: 262/623-0300 Email: paula@armorshieldus.com Contractor License # IL1707 Exp. 4/18/2026

Sincerely,

Sean Keane