



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2046192
Permit #: 00007-2026UPG
Request Rec'd: 01/02/2026
Approval Date: 01/04/2026 DS
Permit Expires: 07/07/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity:	FACILITY - name and address where tanks are located:
Speedway, LLC P.O. Box 1500 Springfield, OH 45501 Clark County Contact: Zachary Davis 937/203-7827	Speedway #7412 1110 Irving Park Road Bensenville, IL 60106 Du Page County Contact: Andrew Wagner 630/616-7611

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	20,000	Currently in use	Federal
2	Gasoline - Premium	8,000	Currently in use	Federal
3	E85	4,000	Currently in use	Federal
4	B-11	12,000	Currently in use	Federal
5	Gasoline - Regular	20,000	Currently in use	Federal
6	B-11	20,000	Currently in use	Federal
7	B-11	20,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Alarm	Removing
Overfill Prevention Device	Overfill Drop Tube Valve - East	Replacing - Overfill Prev Device - Overfill Drop Tube Valve - East
Overfill Prevention Device	Overfill Drop Tube Valve - West	Replacing - Overfill Prev Device - Overfill Drop Tube Valve - West
Spill Containment Device	Double Wall Spill Bucket - East	Replacing - Spill Contain Device - Single Wall Spill Bucket - East
Spill Containment Device	Double Wall Spill Bucket - West	Replacing - Spill Contain Device - Single Wall Spill Bucket - West

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Alarm	Removing
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Alarm	Removing
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Alarm	Removing
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Alarm	Removing
Overfill Prevention Device	Overfill Drop Tube Valve - East	Replacing - Overfill Prev Device - Overfill Drop Tube Valve - East
Overfill Prevention Device	Overfill Drop Tube Valve - West	Replacing - Overfill Prev Device - Overfill Drop Tube Valve - West
Spill Containment Device	Double Wall Spill Bucket - East	Replacing - Spill Contain Device - Single Wall Spill Bucket - East
Spill Containment Device	Double Wall Spill Bucket - West	Replacing - Spill Contain Device - Single Wall Spill Bucket - West

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Alarm	Removing
Overfill Prevention Device	Overfill Drop Tube Valve - East	Replacing - Overfill Prev Device - Overfill Drop Tube Valve - East
Overfill Prevention Device	Overfill Drop Tube Valve - West	Replacing - Overfill Prev Device - Overfill Drop Tube Valve - West
Spill Containment Device	Double Wall Spill Bucket - East	Replacing - Spill Contain Device - Single Wall Spill Bucket - East
Spill Containment Device	Double Wall Spill Bucket - West	Replacing - Spill Contain Device - Single Wall Spill Bucket - West

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Alarm	Removing
Overfill Prevention Device	Overfill Drop Tube Valve - East	Replacing - Overfill Prev Device - Overfill Drop Tube Valve - East
Overfill Prevention Device	Overfill Drop Tube Valve - West	Replacing - Overfill Prev Device - Overfill Drop Tube Valve - West
Spill Containment Device	Double Wall Spill Bucket - East	Replacing - Spill Contain Device - Single Wall Spill Bucket - East
Spill Containment Device	Double Wall Spill Bucket - West	Replacing - Spill Contain Device - Single Wall Spill Bucket - West

Summary of Work

The site has multiple fails on spill and drop tubes so changing all the spills and drop tubes on all the tanks.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

America Petropump Services LLC d/b/a Ampsco Services 4075 Fox Valley Center Dr., Unit 9 Aurora, IL 60504	Contact Person: Ravindra Penmatsa Phone: 312/286-6722 Email: ravi@ampsco.net Contractor License # IL002420 Exp. 5/22/2027
--	--

Sincerely,



Daniel Starks