



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	2007980
Permit #:	00035-2026UPG
Request Rec'd:	01/07/2026
Approval Date:	01/08/2026 SB
Permit Expires:	07/08/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: HPT TA Properties, LLC 24601 Center Ridge Road Westlake, OH 44145 (None) County Contact: Bonnie Parrino 440/808-7268	FACILITY - name and address where tanks are located: Travel Centers of America 19 N 430 Rte. 20 Hampshire, IL 60140 Kane County Contact: Marc Miles 440/683-4550
--	---

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Diesel Fuel	20,000	Currently in use	Federal
4	Diesel Fuel	20,000	Currently in use	Federal
5	Diesel Fuel	20,000	Currently in use	Federal

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Double Wall A.O. Smith	Replacing - Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX
Piping	Single Wall Transition Sump	Replacing - Piping - Single Wall Transition Sump
↳ Leak Detection - Piping	Sump Sensor	Reusing Existing

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Double Wall A.O. Smith	Replacing - Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX
Piping	Single Wall Transition Sump	Replacing - Piping - Single Wall Transition Sump
↳ Leak Detection - Piping	Sump Sensor	Reusing Existing

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Double Wall A.O. Smith	Replacing - Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX

Summary of Work

Removing and replacing less than 20' of existing double wall FRP to accommodate new bio blend system. Also replacing transition sump adjacent to tank pad. Sensor in existing sump will be reinstalled.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 815/209-6640 Email: natem@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2026

Sincerely,



Shelly Bradley