



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY
Facility #: 2028824
Permit #: 01318-2025UPG
Request Rec'd: 10/08/2025
Approval Date: 10/08/2025 DS
Amended Date: 01/12/2026 DS
Permit Expires: 04/08/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity:	FACILITY - name and address where tanks are located: Penske Truck Leasing 650 West 172nd Street South Holland, IL 60473 Cook County Contact: Troy Colbert 610/775-6406
Penske Truck Leasing Co., LP Route 10 Green Hills Reading, PA 19603 Contact: Morgan McCusker 610/775-6409	

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	20,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Replacing - Leak Detect - Piping - Sump Sensor
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root EMC with CSLD
Leak Detection - Tank	Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor - STP sump sensor	Replacing - Leak Detect - Tank - Hydrostatic Reservoir Interstitial Monitoring Sensors
Leak Detection - Tank	Required Other Veeder Root TLS 450 Plus Monitor only for sensors	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus

Dispensers on the Permit

Dispenser	Action
1/2	Sump / Sensors Changing
1-Sat	Sump / Sensors Changing
2-Sat	Sump / Sensors Changing

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	Replacing - Leak Detect - Piping - Sump Sensor with positive shutdown

Dispenser 1-Sat Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	Replacing - Leak Detect - Piping - Sump Sensor

Dispenser 2-Sat Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	Replacing - Leak Detect - Piping - Sump Sensor

Summary of Work

Installing new TLS 450 plus, and smart sensors.

Special Contingencies**Amendment Reason:**

STP sump sensor not on permit, adding

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 630/484-7374 Email: KeenanA@andersonpump.com Contractor License # IL002275 Exp. 5/21/2026

Sincerely,



Daniel Starks