



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
[www.sfm.illinois.gov](http://www.sfm.illinois.gov)  
[SFM.DPCS@illinois.gov](mailto:SFM.DPCS@illinois.gov)  
**Amended**

**FOR OFFICE USE ONLY**  
Facility #: 2019631  
Permit #: 01402-2025UPG  
Request Rec'd: 10/22/2025  
Approval Date: 10/22/2025 DS  
Amended Date: 01/12/2026 DS  
Permit Expires: 04/22/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Mac's Convenience Stores, LLC 1100 Situs Court, Suite 100 Raleigh, NC 27606 (None) County Contact: Michele Alvarado 773/456-5280	<b>FACILITY</b> - name and address where tanks are located: Circle K #4700175 196 South Kinzie Bradley, IL 60915 Kankakee County Contact: Robert Granger 984/389-1765
--	---

**Tanks on the Permit**

<b>Tank #</b>	<b>Product</b>	<b>Capacity</b>	<b>Tank Status</b>	<b>Regulated Status</b>
5	Gasoline - Regular	12,000	Currently in use	Federal
6	Gasoline - Regular	10,000	Currently in use	Federal
7	Gasoline - Premium	10,000	Currently in use	Federal

## Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Flexible Non-Corrosive	Replacing - Corrosion Prot - Piping - Fiberglass Non-Corrosive
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Incon TS 550 with SCALD
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Ball Valves	New
Piping	Flex Connector Steel	Replacing - Piping - Flex Connector Steel
Piping	Flexible Double Wall NUPI Smartflex	Replacing - Piping - Fiberglass Single Wall Piping
Piping	Other Steel Riser	New
Piping	Other Submersible Pump	New
Piping	Single Wall STP/Tanktop Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Double Wall Spill Bucket

## Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Flexible Non-Corrosive	Replacing - Corrosion Prot - Piping - Fiberglass Non-Corrosive
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - Disp 5/6	Removing
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - Disp 5/6	Removing
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - Disp 5/6	Removing
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - Disp 5/6	Removing
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Incon TS 550 with SCALD
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Ball Valves	New
Piping	Flex Connector Steel	Replacing - Piping - Flex Connector Steel
Piping	Flexible Double Wall NUPI Smartflex	Replacing - Piping - Fiberglass Single Wall Piping
Piping	Other Steel Riser	New
Piping	Other Submersible Pump	New
Piping	Single Wall STP/Tanktop Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Double Wall Spill Bucket

## Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Flexible Non-Corrosive	Replacing - Corrosion Prot - Piping - Fiberglass Non-Corrosive
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - Disp 1/2	Removing
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - Disp 1/2	Removing
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - Disp 1/2	Removing
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - Disp 1/2	Removing
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Incon TS 550 with SCALD
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Ball Valves	New
Piping	Flex Connector Steel	Replacing - Piping - Flex Connector Steel
Piping	Flexible Double Wall NUPI Smartflex	Replacing - Piping - Fiberglass Single Wall Piping
Piping	Other Steel Riser	New
Piping	Other Submersible Pump	New
Piping	Single Wall STP/Tanktop Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Double Wall Spill Bucket

## Dispensers on the Permit

Dispenser	Action
1/2	Sump / Sensors Changing
3/4	Sump / Sensors Changing
5/6	Sump / Sensors Changing

## Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

## Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

## Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

**Summary of Work**

All Tank and Island locations to remain the same. Replacing product lines, overspill buckets, overfill drop tubes, Submersibles, STP sumps/sensors, UDC sumps/sensors, TLS 450 plus. (1) New E-Stop as per attached drawing. 1/12/2026  
 Tank # 6 = Under "Leak Detection Piping" ADDING : Electronic Pressurized Line Leak Detection

**Special Contingencies****Amendment Reason:**

Tank # 6 = Under "Leak Detection Piping" ADDING : Electronic Pressurized Line Leak Detection

**PERSON, FIRM OR COMPANY PERFORMING WORK:**

Anderson Pump Service, Inc.  
 19659 South 97th Avenue  
 Mokena, IL 60448

Contact Person: Ron Anderson  
 Phone: 708/560-5590  
 Email: Keith@Andersonpump.com  
 Contractor License # IL002275 Exp. 5/21/2026

Sincerely,

Daniel S. Starks

Daniel Starks

**For Office Use Only****Tank 5 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Not Installed STP/Tanktop Sump	Removing

**Tank 6 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Not Installed STP/Tanktop Sump	Removing

**Tank 7 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Not Installed STP/Tanktop Sump	Removing

**Dispenser 1/2 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing

**Dispenser 3/4 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing

**Dispenser 5/6 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing