



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 3016639
Permit #: 00055-2026UPG
Request Rec'd: 01/14/2026
Approval Date: 01/14/2026 DS
Permit Expires: 07/14/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS	FACILITY
- Corporation, partnership, or other business entity: G & M Distributors, Inc. 200 N. Linwood P.O. Box 509 Galesburg, IL 614012050 Knox County Contact: Sebastian Schwabe 309/299-7528	- name and address where tanks are located: G & M Distributors, Inc. 200 N. Linwood Galesburg, IL 61401 Knox County Contact: Sebastian Schwabe 308/299-7528

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Diesel Fuel	10,000	Currently in use	Federal
4	Gasoline - Regular	4,000	Currently in use	Federal

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Required Other Veeder Root TLS 350 Monitor only for sensors	Replacing - Leak Detect - Tank - Automatic Tank Gauging EBW Auto-Stik 950

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Required Other Veeder Root TLS 350 Monitor only for sensors	Replacing - Leak Detect - Tank - Automatic Tank Gauging EBW Auto-Stik 950

Summary of Work

Replacing the Auto-Stik 950 with a TLS-350

Special Contingencies

NOTE: Equipment listed as replacing the current ATG is for a TLS-350 console ONLY to monitor the existing tank interstitial sensors.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Illinois Oil Marketing Equipment, Inc. 850 Brenkman Drive Pekin, IL 61554	Contact Person: Bryan Estes Phone: 309/347-1819 Email: amannino@iome.com Contractor License # IL1293 Exp. 2/4/2026

Sincerely,

Daniel G. Starks

Daniel Starks