



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY
Facility #: 2000233
Permit #: 00060-2026UPG
Request Rec'd: 01/15/2026
Approval Date: 01/15/2026 DS
Amended Date: 01/16/2026 DS
Permit Expires: 07/15/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS	FACILITY
- Corporation, partnership, or other business entity: Speedway, LLC P.O. Box 1500 Springfield, OH 45501 Clark County Contact: Zachary Davis 937/203-7827	- name and address where tanks are located: Speedway #7372 2932 Belvidere Street Waukegan, IL 60085 Lake County 08-30-215-006 Contact: Travis Powell 937/863-6513

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Regular	10,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Other Fiberglass Riser	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

Tank# 5 B-11 = Install a new Fill riser, Replacing overspill bucket and overfill drop tube. AMENDMENT = Had some confusion on what work was already done and what still needs to be taken care of at this site. Diesel# 5 had the drop tube replaced by an Anderson Tech. Regular# 2 is the tank that needs the Fill Riser, Overspill Bucket, and Overfill Drop Tube replaced.

Special Contingencies

Amendment Reason:

Had some confusion on what work was already done and what still needs to be taken care of at this site. Diesel# 5 had the drop tube replaced by an Anderson Tech. Regular# 2 is the tank that needs the Fill Riser, Overspill Bucket, and Overfill Drop Tube replaced.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 708/560-5590 Email: Keith@Andersonpump.com Contractor License # IL002275 Exp. 5/21/2026

Sincerely,

Daniel G. Starks

Daniel Starks