



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2021423  
Permit #: 00065-2026REM  
Request Rec'd: 01/16/2026  
Approval Date: 01/16/2026 DS  
Permit Expires: 07/16/2026

## **Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances**

Permission to remove underground storage tank piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity:	<b>FACILITY</b> - name and address where tanks are located: Mobil 17500 Dixie Highway Homewood, IL 60430 Cook County 29-31-103-019-0000 Contact: Atif Razzaq 773/750-3004
Homewood Business, Inc. 17500 Dixie Hwy Homewood, IL 60430 (None) County Contact: Mazhar Bhatti 708/699-9237	

### **Tanks on the Permit For Piping Only**

<b>Tank #</b>	<b>Capacity</b>	<b>Product</b>	<b>Last Used Date</b>
1	8,000	Gasoline - Premium	
2	8,000	Gasoline - Regular	
3	10,000	Gasoline - Regular	

### **Summary of Work**

REMOVING ALL EXISTING PRODUCT PIPING TO ALLOW FOR TANK TOP /PIPING UPGRADE.

### **Special Contingencies**

After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Cardinal Compliance LLC 415 W. Golf Rd. Unit 28M-N Arlington Heights, IL 60005	Contact Person: Chris Derro Phone: 708/717-2676 Email: cderro@cardinalcompliance.net Contractor License # IL002418 Exp. 3/21/2027

Sincerely,

Daniel Starks