



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 3038384
Permit #: 00066-2026ABN
Request Rec'd: 01/13/2026
Approval Date: 01/16/2026 DS
Permit Expires: 07/16/2026

Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS	FACILITY
- Corporation, partnership, or other business entity: Edward R. Shimp 428 La Prairie Road Sparland, IL 61565 (None) County Contact: Paul Allen 309/635-6160	- name and address where tanks are located: Shimp Farms 428 La Prairie Road Sparland, IL 61565 Marshall County 08-22-400-002 Contact: Edward Shimp 309/635-6160

Tanks on the Permit

* A combination of inert fill material is not allowed. The listed inert fill material is only allowed to fill the abandoned tank.

Tank #	Capacity	Product	Fill Material *
1	8,200	Diesel Fuel	Inert material mixed with portland cement

Explanation of Waiver for Abandonment

Excavate to tank top. Abandon in-place one (1) 8,200 gallon underground storage tank in accordance with state of Illinois 175 regulations. Obtain State of Illinois abandonment permit. Purge, clean and fill tank with slurry mix. Disconnect, drain and cap product and vent piping. Remove submersible pump and tank monitor. Backfill and recover with new reinforced concrete.

Location of Tanks Being Abandoned

Tank is located in close proximity to an existing building as shown in site plan. Attempting to remove would undermine the structural integrity of the building.

CONTAMINATED SITE!

IEMA Number

2026-0023

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Armor Shield of Wisconsin 3965 Hillside Road Slinger, WI 53086	Contact Person: Clayton Bennett Phone: 262/623-0300 Email: paula@armorshieldus.com Contractor License # IL1707 Exp. 4/18/2026

Sincerely,

Daniel G. Starks

Daniel Starks