



City of Chicago
Department of Public Health
 333 South State Street, Room 200
 Chicago, IL 60604
 312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	2021469
Permit #:	00089-2026UPG
Request Rec'd:	01/22/2026
Approval Date:	01/26/2026 SK
Permit Expires:	07/28/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: 4355, LLC 3716 W. North Ave. Stone Park, IL 60165 Cook County Contact: Mike Scali 773/544-1913	FACILITY - name and address where tanks are located: Citgo 4357 W. Belmont Chicago, IL 60651 Cook County Contact: Mike Scali 773/544-1913
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	6,000	Currently in use	Federal
2	Gasoline - Regular	4,000	Currently in use	Federal
3	Gasoline - Premium	4,000	Currently in use	Federal
4	Diesel Fuel	3,000	Currently in use	Federal
5	Diesel Fuel	2,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350R with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350R

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350R with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350R

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350R with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350R

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350R with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350R

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350R with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350R

Summary of Work

Installing CSLD chip in existing TLS-350R.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Cardinal Compliance LLC 415 W. Golf Rd. Unit 28M-N Arlington Heights, IL 60005	Contact Person: Chris Derro Phone: 708/717-2676 Email: cderro@cardinalcompliance.net Contractor License # IL002418 Exp. 3/21/2027

Sincerely,

Sean Keane