



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	2025062
Permit #:	00099-2026UPG
Request Rec'd:	01/26/2026
Approval Date:	01/26/2026 DS
Permit Expires:	07/28/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

<p>OWNER OF TANKS - Corporation, partnership, or other business entity: A & S Gas Station 14941 Dixie Highway Harvey, IL 60426 Cook County Contact: Ali Salem 773/879-6767</p>	<p>FACILITY - name and address where tanks are located: Harvey Citgo 14941 Dixie Highway Harvey, IL 60426 Cook County 29-07-319-026-0000 Contact: Nikopoulos Chris 708/339-6292</p>
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Gasoline - Regular	12,000	Currently in use	Federal

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Piping	Ball Valves	New
Piping	Flex Connector Steel	New
Piping	Other Submersible Pump	New

Summary of Work

Replacing the Regular tank's submersible motor assembly, mechanical leak detector, ball valve, and flex connector

Special Contingencies

NOTE: A sump must be installed if not already existing

PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>B & K Equipment Company 2939 175th Street Lansing, IL 60438</p>	<p>Contact Person: DJ White Phone: 708/474-3344 Email: ben.olthoff@bkequip.com Contractor License # IL1207 Exp. 2/14/2026</p>

Sincerely,

Daniel Starks