



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 217/785-1020  
 www.sfm.illinois.gov  
 SFM.DPCS@illinois.gov

<b>FOR OFFICE USE ONLY</b>	
Facility #:	1047505
Permit #:	00149-2026UPG
Request Rec'd:	02/10/2026
Approval Date:	02/10/2026 DS
Permit Expires:	08/11/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Michlig Agricenter, Inc. 105 1St St Manlius, IL 61338 Bureau County Contact: Joe Michlig 815/445-6921	<b>FACILITY</b> - name and address where tanks are located: Michlig Energy 20805 IL Hwy 40 Sheffield, IL 61361 Bureau County 08-21-200-003 Contact: Mike Dykstra 815/303-6926
---	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	10,000	Currently in use	Federal
2	Dyed Diesel	4,000	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Alarm	Removing

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Alarm	Removing

**Summary of Work**

Permit application to remove overfill alarm only as a form of overfill prevention as suggested by OSFM inspector, site will maintain overfill valves as their for of overfill protection

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Seneca Companies, Inc. 4140 East 14th Street PO Box 3360 Des Moines, IA 50313	Contact Person: Glen Davis Phone: 563/340-5216 Email: gdavis@senecaco.com Contractor License # IL598 Exp. 2/23/2026

Sincerely,

Daniel Starks