



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**

1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 7021714
Permit #: 00152-2026REM
Request Rec'd: 02/10/2026
Approval Date: 02/10/2026 DS
Permit Expires: 08/11/2026

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances

Permission to remove underground storage tank piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

<p>OWNER OF TANKS - Corporation, partnership, or other business entity: Sharlin and Nirav Patel 407 S. Main Street Zeigler, IL 62999 (None) County Contact: Sharlin M Patel 636/388-1546</p>	<p>FACILITY - name and address where tanks are located: Zeigler Food & Gas 407 S. Main Highway 148 & Main Street Zeigler, IL 62999 Franklin County 10-24-351-001 Contact: Mith Mevada 636/388-1546</p>
---	---

IEMA Number
1997-1822

Tanks on the Permit For Piping Only

Tank #	Capacity	Product	Last Used Date
3	12,000	Gasoline - Regular	05/15/2025
4	12,000	Diesel Fuel	05/15/2025

Special Contingencies

After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>Robert Ellis & Sons d/b/a Ellis Excavating, Inc. 1703 North 7th Street Murphysboro, IL 62966</p>	<p>Contact Person: Mike Ellis Phone: 618/713-0765 Email: ellisexcavating35@live.com Contractor License # IL980 Exp. 5/21/2026</p>

Sincerely,

Daniel Starks