



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 217/785-1020  
 www.sfm.illinois.gov  
 SFM.DPCS@illinois.gov

<b>FOR OFFICE USE ONLY</b>	
Facility #:	2025864
Permit #:	00154-2026CAT
Request Rec'd:	02/11/2026
Approval Date:	02/11/2026 DS
Permit Expires:	08/11/2026

**Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Brake Time IL Properties, LLC 6300 Richmond Avenue, Suite 300 Houston, TX 77057 (None) County Contact: Omair Bashir 832/539-8190	<b>FACILITY</b> - name and address where tanks are located: Brake Time 103 N. Ridge Road Minooka, IL 60447 Grundy County 03-02-200-020 Contact: Muhammad Akhtar 832/539-8190
--	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	12,000	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector
Corrosion Protection - Tank	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Tank - STIP3 Cathodic Protection with Dielectric Coating

**NACE Certified Designer**  
**NACE Certified Designer Number**  
**Method of Integrity Assessment of Tanks**

**Special Contingencies**

**Summary of Work**

Install three 20 pound high potential magnesium anodes on the regular 1 tank at 3' spacing, 1' below tank bottom, through a mini test station and bonding to the tank top. Install four 5 pound high potential magnesium anodes through a sac test station on each reg 1 and pre STP flexible connector.

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Tanknology 880 Church Road Elgin, IL 60123	Contact Person: Linda Przydzial Phone: 512/380-7117 Email: dhollander@tanknology.com Contractor License # IL2089 Exp. 3/4/2026

Sincerely,

*Daniel J. Starks*

Daniel Starks