



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 217/785-1020  
 www.sfm.illinois.gov  
 SFM.DPCS@illinois.gov

<b>FOR OFFICE USE ONLY</b>	
Facility #:	3017358
Permit #:	00164-2026UPG
Request Rec'd:	02/12/2026
Approval Date:	02/14/2026 DS
Permit Expires:	08/14/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Casey's Retail Company 3305 SE Delaware Ave. P.O. Box 3004 Ankeny, IA 50021 Contact: Lee Lytle 515/446-6231	<b>FACILITY</b> - name and address where tanks are located: Casey's General Store #1422 102 East Second Street Glasford, IL 61533 Peoria County 19-22-301-009 Contact: Patty Schubert 515/965-6238
--	---

**Tanks on the Permit For Piping Only**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
2	Diesel Fuel	6,000	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	New

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	New

**Dispensers on the Permit**

Dispenser	Action
1/2	Replacing - 1/2
3/4	Replacing - 3/4

**Dispenser 1/2 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Reusing Existing
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

**Dispenser 3/4 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Reusing Existing


**Summary of Work**

Remove existing two fueling dispensers and install two new fueling dispensers.  
Breakout island 1/2, lower shear valves, install flex connector, install sump sensor, and pour concrete island. Line and leak detecor test plus hydro test UDC 1/2.

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 414/491-1002 Email: mikem@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2026

Sincerely,



Daniel Starks

<b>For Office Use Only</b>		
<b>Dispenser 1/2 Equipment</b>		
<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Required in Single Wall UDC Sump	Removing
<b>Dispenser 3/4 Equipment</b>		
<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>