



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 217/785-1020  
 www.sfm.illinois.gov  
 SFM.DPCS@illinois.gov

<b>FOR OFFICE USE ONLY</b>	
Facility #:	2040615
Permit #:	00166-2026UPG
Request Rec'd:	02/12/2026
Approval Date:	02/14/2026 DS
Permit Expires:	08/14/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>OWNER OF TANKS</b>          - Corporation, partnership, or other business entity:          Meijer Great Lakes Limited Partnership          2929 Walker Avenue, NW          Grand Rapids, MI 495449428          Contact: Erik Petrovoskis 616/735-7101</p>	<p><b>FACILITY</b>          - name and address where tanks are located:          Meijer Gas Station #215          735 E. Boughton Road          Bolingbrook, IL 60440          Will County          12-02-01-401-021-0000          Contact: Express Team Lead 630/783-5329</p>
---	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Regular	20,000	Currently in use	Federal

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve - Northwest	Replacing - Overfill Prev Device - Overfill Drop Tube Valve - Northwest
Piping	Other Steel Riser	New
Spill Containment Device	Double Wall Spill Bucket - Northwest	Replacing - Spill Contain Device - Single Wall Spill Bucket - Northwest

**Summary of Work**

Replacing north regular spill container, drop tube, and riser.

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: DJ White Phone: 708/474-3344 Email: dj.white@Bkequip.com Contractor License # IL1207 Exp. 2/14/2028

Sincerely,

Daniel Starks