



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 217/785-1020  
 www.sfm.illinois.gov  
 SFM.DPCS@illinois.gov

<b>FOR OFFICE USE ONLY</b>	
Facility #:	5025670
Permit #:	00172-2026UPG
Request Rec'd:	02/16/2026
Approval Date:	02/17/2026 DS
Permit Expires:	08/18/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>OWNER OF TANKS</b>          - Corporation, partnership, or other business entity:          Casey's Retail Company          3305 SE Delaware Ave. P.O. Box 3004          Ankeny, IA 50021          Contact: Lee Lytle 515/446-6231</p>	<p><b>FACILITY</b>          - name and address where tanks are located:          Casey's General Store #1533          184 East State Street          Palmyra, IL 62674          Macoupin County          19-000-826-00          Contact: Jill Reams-Widder 515/965-6238</p>
---	---

**Tanks on the Permit For Piping Only**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
2	Diesel Fuel	6,000	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	Replacing - Piping - Flex Connector Steel

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	Replacing - Piping - Flex Connector Steel

**Summary of Work**

We are lowering Island #1/2 to adjust for ADA regulations. Flex connectors may need to be replaced. Pour back slope.

**Special Contingencies**

**NOTE: UDC must be installed if not already existing**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Seneca Companies, Inc. 4140 East 14th Street PO Box 3360 Des Moines, IA 50313	Contact Person: Natasha Newbury Phone: 563/529-3378 Email: dburk@senecaco.com Contractor License # IL598 Exp. 2/23/2026

Sincerely,

Daniel Starks