



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	7021714
Permit #:	00177-2026UPG
Request Rec'd:	02/16/2026
Approval Date:	02/17/2026 DS
Permit Expires:	08/18/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Sharlin and Nirav Patel 407 S. Main Street Zeigler, IL 62999 (None) County Contact: Sharlin M Patel 636/388-1546	FACILITY - name and address where tanks are located: Zeigler Food & Gas 407 S. Main Highway 148 & Main Street Zeigler, IL 62999 Franklin County 10-24-351-001 Contact: Mith Mevada 636/388-1546
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Gasoline - Regular	12,000	Out of service	Federal
4	Diesel Fuel	12,000	Out of service	Federal

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flexible Double Wall OmegaFlex DoubleTrac	Replacing - Piping - Flexible Double Wall
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flexible Double Wall OmegaFlex DoubleTrac	Replacing - Piping - Flexible Double Wall
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

Dispensers on the Permit

Dispenser	Action
1/2	Sump / Sensors Changing
3/4	Sump / Sensors Changing

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

Summary of Work

- 1) Blow fuel from impact valves through sub motors back into the tanks with Nitrogen.
- 2) Remove dispensers and submergible pumps for excavator (Seperate Permit) to remove the product lines.
- 3) Install new tank top sumps, install new dispenser sumps.
- 4) Run dual wall Omega Flex product lines.
- 5) Electricitians to run conduits
- 6) Perform Air and Hydrostatic Sump test with OSFM.
- 7) Supervise back fill of sumps.
- 8) Return when concrete is poured, set dispensers, pipe and wire up, purge and calibrate.
- 9) Perform final inspection with OSFM and place in service

Special Contingencies

NOTES: Piping to be removed under permit 00152-2026REM. Dispensers must be at least 10' from all buildings and property lines.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Mid-South Steel Products, Inc. 2071 Corporate Circle Drive PO Box 277 Cape Girardeau, MO 63703	Contact Person: Billy Thorne Phone: 573/335-5529 Email: billy@midsouthsteel.com Contractor License # IL1194 Exp. 8/17/2026

Sincerely,



Daniel Starks

For Office Use Only

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Required in Single Wall STP/Tanktop Sump	Removing

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Required in Single Wall STP/Tanktop Sump	Removing

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Required in Single Wall UDC Sump	Removing

Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Required in Single Wall UDC Sump	Removing