



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	1000952
Permit #:	00179-2026REM
Request Rec'd:	02/16/2026
Approval Date:	02/17/2026 DS
Permit Expires:	08/18/2026

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances

Permission to remove underground storage tank piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176 . The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Dohrn Terminals, LLC 625 3rd Avenue Rock Island, IL 61201 Rock Island County Contact: Troy Winthurst 309/794-0723	FACILITY - name and address where tanks are located: Dohrn Transfer Company, LLC 1422 W Rt 30 Rock Falls, IL 61071 Whiteside County Contact: Jeremiah Kellermann 815/625-1902
---	--

Tanks on the Permit For Piping Only

Tank #	Capacity	Product	Last Used Date
8	12,000	Diesel Fuel	

Summary of Work

All containment sumps and fuel lines are to be removed and replaced with new FE Petro equipment. Sensors to be added to all new containments, electronic leak detection to be installed, as well as positive shut down. The layout of the fuel system components will remain the same. No work is to be performed on the vent piping.

Special Contingencies

After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Illowa Enterprises, Inc. 2703 4th Avenue Moline, IL 61265	Contact Person: James Saddoris Phone: 309/762-1729 Email: illowa@illowaent.com Contractor License # IL981 Exp. 5/1/2026

Sincerely,



Daniel Starks