



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 217/785-1020  
 www.sfm.illinois.gov  
 SFM.DPCS@illinois.gov

<b>FOR OFFICE USE ONLY</b>	
Facility #:	1000952
Permit #:	00181-2026UPG
Request Rec'd:	02/17/2026
Approval Date:	02/17/2026 DS
Permit Expires:	08/18/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Dohrn Terminals, LLC 625 3rd Avenue Rock Island, IL 61201 Rock Island County Contact: Troy Winthurst 309/794-0723	<b>FACILITY</b> - name and address where tanks are located: Dohrn Transfer Company, LLC 1422 W Rt 30 Rock Falls, IL 61071 Whiteside County Contact: Jeremiah Kellermann 815/625-1902
---	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
8	Diesel Fuel	12,000	Currently in use	Federal

**Tank 8 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Piping	Flexible Double Wall A.P.T. Poly Tech P175SC	Replacing - Piping - Flexible Double Wall A.P.T. Poly Tech P175SC
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Leak Detection - Piping	Sump Sensor with positive shutdown	Replacing - Leak Detect - Piping - Sump Sensor
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

**Dispensers on the Permit**

Dispenser	Action
1/2	Sump / Sensors Changing
2S	Sump / Sensors Changing

**Dispenser 1/2 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
Leak Detection - Piping	Sump Sensor with positive shutdown	New

**Dispenser 2S Equipment**

<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

**Summary of Work**

All containment sumps and fuel lines are to be removed and replaced with new FE Petro equipment. Sensors to be added to all new containments, electronic leak detection to be installed, as well as positive shut down. The layout of the fuel system components will remain the same. No work is to be performed on the vent piping.

**Special Contingencies**

**NOTE: Dispensers must be at least 10' from all buildings and property lines**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Illowa Enterprises, Inc. 2703 4th Avenue Moline, IL 61265	Contact Person: James Saddoris Phone: 309/762-1729 Email: illowa@illowaent.com Contractor License # IL981 Exp. 5/1/2026

Sincerely,

  
\_\_\_\_\_

Daniel Starks

<b>For Office Use Only</b>		
<b>Dispenser 1/2 Equipment</b>		
<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Required in Single Wall UDC Sump	Removing
<b>Dispenser 2S Equipment</b>		
<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Required in Single Wall UDC Sump	Removing