



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 217/785-1020  
 www.sfm.illinois.gov  
 SFM.DPCS@illinois.gov

<b>FOR OFFICE USE ONLY</b>	
Facility #:	3033521
Permit #:	00185-2026CAT
Request Rec'd:	02/17/2026
Approval Date:	02/17/2026 DS
Permit Expires:	08/18/2026

**Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Casey's Retail Company 3305 SE Delaware Ave. P.O. Box 3004 Ankeny, IA 50021 Contact: Lee Lytle 515/446-6231	<b>FACILITY</b> - name and address where tanks are located: Casey's General Store #2360 411 West Front Street Roanoke, IL 61561 Woodford County Contact: Jim Reams-Widder 515/965-6238
--	--

**Tanks on the Permit For Piping Only**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
2	Diesel Fuel	10,000	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing

**NACE Certified Designer**  
**NACE Certified Designer Number**  
**Method of Integrity Assessment of Tanks**

**Special Contingencies**

**Summary of Work**

Removing Cathodic Protection after Contractor has made containments water tight/dry

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Midwest Tank Testing, LLC 2008 Medical Center Dr Monticello, IL 61856	Contact Person: Stephen T. Hall Phone: 217/714-4305 Email: Midwesttanktestingst@aol.com Contractor License # IL002461 Exp. 1/2/2028

Sincerely,

*Daniel J. Starks*

Daniel Starks