



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	3007442
Permit #:	00206-2026UPG
Request Rec'd:	02/20/2026
Approval Date:	02/20/2026 DS
Permit Expires:	08/20/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: West Central FS, Inc. 1445 Monmouth Blvd. Galesburg, IL 61401 Knox County Contact: Tricia Faudree 309/627-2394	FACILITY - name and address where tanks are located: Rozetta 2009 State Highway 94 Jct. Route 164 & 94 Oquawka, IL 61469 Henderson County 04-20-400-005 Contact: Wendell Oliver 309/627-2394
--	--

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Diesel Fuel	12,000	Currently in use	Federal

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	New

Dispensers on the Permit

Dispenser	Action
5/6 DSL	Sump / Sensors Changing
6S	Sump / Sensors Changing

Dispenser 5/6 DSL Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	Replacing - Leak Detect - Piping - Sump Sensor with positive shutdown

Dispenser 6S Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	Replacing - Leak Detect - Piping - Sump Sensor with positive shutdown

Summary of Work

INSTALLED NEW SUMP SENSOR IN TANK SUMP AND DISPENSER SUMPS WITH POSITVE SHUT OFF.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

R. L. Hoener Company
2923 Gardner Expressway P. O. Box 1086
Quincy, IL 62305

Contact Person: Marty Jackson
Phone: 217/223-2190
Email: kmajors@rlhoener.com
Contractor License # IL2021 Exp. 5/22/2026

Sincerely,



Daniel Starks

For Office Use Only

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Required in Single Wall STP/Tanktop Sump	Removing

Dispenser 5/6 DSL Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Required in Single Wall UDC Sump	Removing

Dispenser 6S Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Required in Single Wall UDC Sump	Removing