



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	5018853
Permit #:	00207-2026UPG
Request Rec'd:	02/20/2026
Approval Date:	02/20/2026 DS
Permit Expires:	08/20/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

<p>OWNER OF TANKS - Corporation, partnership, or other business entity: Sumbal Corporation 705 W. Clinton Street Rushville, IL 62681 Schuyler County Contact: Ahmed Nasir 217/770-4046</p>	<p>FACILITY - name and address where tanks are located: MNA Food Mart 705 West Clinton Street Route 24 & 67 Rushville, IL 62681 Schuyler County 07-25-377-009 Contact: Ahmed Nasir 217/773-3867</p>
---	---

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Gasoline - Regular	8,000	Currently in use	Federal

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Other Non-vented check valve	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection

Summary of Work

REMOVE ELECTRONIC LINE LEAK DETECTOR WITH MECHANICAL LINE LEAK DETECTOR.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>R. L. Hoener Company 2923 Gardner Expressway P. O. Box 1086 Quincy, IL 62305</p>	<p>Contact Person: Marty Jackson Phone: 217/223-2190 Email: kmajors@rlhoener.com Contractor License # IL2021 Exp. 5/22/2026</p>

Sincerely,

Daniel Starks