



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 217/785-1020  
 www.sfm.illinois.gov  
 SFM.DPCS@illinois.gov

<b>FOR OFFICE USE ONLY</b>	
Facility #:	3001268
Permit #:	00209-2026UPG
Request Rec'd:	02/21/2026
Approval Date:	02/23/2026 DS
Permit Expires:	08/25/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Axis Investments, LLC P.O. Box 436708 Louisville, KY 40253 Jefferson County Contact: Armin Zukanozic 502/546-9403	<b>FACILITY</b> - name and address where tanks are located: Kamla Kaur Management, Inc. d/b/a 1900 N. Knoxville Shell 1900 N. Knoxville Peoria, IL 61603 Peoria County 14-33-452-004 Contact: Sanjit Pandher 502/836-0060
---	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Regular	10,000	Out of service	Federal
3	Gasoline - Regular	8,000	Out of service	Federal

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Ball Valves	New
Piping	Fiberglass Double Wall Ameron Dualoy 3000/LCX	Replacing - Piping - Flexible Double Wall Total Containment Enviroflex non-corrosive
Piping	Flex Connector Steel	New
Piping	Other Steel Riser	New
Piping	Other Submersible Pump	New
Piping	Shear Valves	New
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

### Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Piping	Ball Valves	New
Piping	Fiberglass Double Wall Ameron Dualoy 3000/LCX	Replacing - Piping - Flexible Double Wall Total Containment Enviroflex non-corrosive
Piping	Flex Connector Steel	New
Piping	Other Steel Riser	New
Piping	Other Submersible Pump	New
Piping	Shear Valves	New
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

### Dispensers on the Permit

Dispenser	Action
3/4	Sump / Sensors Changing
5/6	Sump / Sensors Changing
7/8	Sump / Sensors Changing
replacing the one in operation	New

### Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	Replacing - Leak Detect - Piping - Sump Sensor

### Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	Replacing - Leak Detect - Piping - Sump Sensor

### Dispenser 7/8 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	Replacing - Leak Detect - Piping - Sump Sensor

### Dispenser replacing the one in operation Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

### Summary of Work

Installing new FGDW piping from tanks to all dispensers for both tanks.

Installing new UDCs & Stp sumps, installainga beadreau stand alone sensors as positive shutdown sensors in stp sumps only.

### Special Contingencies

**NOTE: Dispensers must be at least 10' from all buildings and property lines.**

PERSON, FIRM OR COMPANY PERFORMING WORK:	
American Petroleum Solutions LLC 7143 Polo Place Loves Park, IL 61111	Contact Person: Haibat Khan Phone: 909/312-9449 Email: apetro.office@gmail.com Contractor License # IL002454 Exp. 5/21/2026

Sincerely,

*Daniel S. Starks*

Daniel Starks

**For Office Use Only**

**Tank 2 Equipment**

<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Required in Single Wall STP/Tanktop Sump	Removing

**Tank 3 Equipment**

<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Required in Single Wall STP/Tanktop Sump	Removing

**Dispenser replacing the one in operation Equipment**

<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
-----------------------	-------------------------	---------------