



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY	
Facility #:	2014713
Permit #:	01385-2025UPG
Request Rec'd:	10/21/2025
Approval Date:	10/21/2025 DS
Amended Date:	02/23/2026 DS
Permit Expires:	04/21/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: RDK Ventures LLC 1120 W. Warner Rd. Tempe, AZ 85284 (None) County Contact: Michele Alvarado 773/456-5280	FACILITY - name and address where tanks are located: Circle K #6802 601 S. Frontage Road Burr Ridge, IL 60521 Du Page County 09-35-400-021 Contact: Harry Cho 812/379-9227
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Gasoline - Regular	12,000	Currently in use	Federal
7	Gasoline - Regular	12,000	Currently in use	Federal
8	Gasoline - Premium	12,000	Currently in use	Federal

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve - West	Replacing - Overfill Prev Device - Overfill Drop Tube Valve - West
Piping	Ball Valves	New
Piping	Flex Connector Steel	New
Piping	Other Steel Riser	New
Spill Containment Device	Double Wall Spill Bucket - West	Replacing - Spill Contain Device - Double Wall Spill Bucket - West

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve - East	Replacing - Overfill Prev Device - Overfill Drop Tube Valve - East
Piping	Ball Valves	New
Piping	Flex Connector Steel	New
Piping	Other Steel Riser	New
Spill Containment Device	Double Wall Spill Bucket - East	Replacing - Spill Contain Device - Double Wall Spill Bucket - East

Tank 8 Equipment

Equipment Type	Permit Equipment	Action
Piping	Ball Valves	New
Piping	Flex Connector Steel	New

Summary of Work

Tanks # 6 and 7 : Regular = Installing new Fill risers, Replacing Overspill buckets and Overfill drop tubes
AMENDED CHANGES : Tanks 6, 7, and 8 = Installing new ball valves and flex connectors in the STP sumps

Special Contingencies

Amendment Reason:


While on site performing permitted work, issues on all (3) tanks ball valves and flex connectors in the STP sumps were brought to Anderson's attention

PERSON, FIRM OR COMPANY PERFORMING WORK:

Anderson Pump Service, Inc.
19659 South 97th Avenue
Mokena, IL 60448

Contact Person: Ron Anderson
Phone: 708/560-5590
Email: Keith@Andersonpump.com
Contractor License # IL002275 Exp. 5/21/2026

Sincerely,



Daniel Starks