



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**

1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2021806  
Permit #: 00216-2026UPG  
Request Rec'd: 02/24/2026  
Approval Date: 02/24/2026 DS  
Permit Expires: 08/25/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for  
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Mac's Convenience Stores, LLC 1100 Situs Court, Suite 100 Raleigh, NC 27606 (None) County Contact: Michele Alvarado 773/456-5280</p>	<p><b>FACILITY</b> - name and address where tanks are located: Circle K #4700177 1952 East Court Street Kankakee, IL 60901 Kankakee County 16-17-04-206-003 Contact: Helen Dickson 984/389-1765</p>
---	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Regular	10,000	Currently in use	Federal
3	Gasoline - Premium	10,000	Currently in use	Federal
4	Gasoline - Regular	10,000	Currently in use	Federal

## Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Flexible Non-Corrosive	Replacing - Corrosion Prot - Piping - Fiberglass Non-Corrosive
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Ball Valves	New
Piping	Flex Connector Steel	New
Piping	Flexible Double Wall NUPI Smartflex	Replacing - Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000/L
Piping	Other Steel Riser	New
Piping	Other Submersible Pump	New
Piping	Single Wall STP/Tanktop Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Double Wall Spill Bucket

## Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Flexible Non-Corrosive	Replacing - Corrosion Prot - Piping - Fiberglass Non-Corrosive
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Ball Valves	New
Piping	Flex Connector Steel	New
Piping	Flexible Double Wall NUPI Smartflex	Replacing - Piping - Fiberglass Single Wall Piping Ameron
Piping	Other Steel Riser	New
Piping	Other Submersible Pump	New
Piping	Single Wall STP/Tanktop Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Double Wall Spill Bucket

## Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Flexible Non-Corrosive	Replacing - Corrosion Prot - Piping - Fiberglass Non-Corrosive
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Ball Valves	New
Piping	Flex Connector Steel	New
Piping	Flexible Double Wall NUPI Smartflex	Replacing - Piping - Fiberglass Single Wall Piping Ameron
Piping	Other Steel Riser	New
Piping	Single Wall STP/Tanktop Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Double Wall Spill Bucket

### Dispensers on the Permit

Dispenser	Action
1/2	Sump / Sensors Changing
3/4	Sump / Sensors Changing
5/6	Sump / Sensors Changing
7/8	Sump / Sensors Changing

### Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

### Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

### Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

### Dispenser 7/8 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

**Summary of Work**


All Tank and Island locations to remain the same. Vent piping to remain (Not being replaced) Replacing product lines, overspill buckets, overfill drop tubes, Submersibles, STP sumps/sensors, UDC sumps/sensors, TLS 450 plus. (2) New E-Stops as per attached drawing.

**Special Contingencies**

**NOTE: A removal permit must be obtained for the piping being replaced.**

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 708/560-5590 Email: Keith@Andersonpump.com Contractor License # IL002275 Exp. 5/21/2026

Sincerely,



Daniel Starks

For Office Use Only		
<b>Tank 2 Equipment</b>		
Equipment Type	Permit Equipment	Action
Piping	Not Installed STP/Tanktop Sump	Removing
<b>Tank 3 Equipment</b>		
Equipment Type	Permit Equipment	Action
Piping	Not Installed STP/Tanktop Sump	Removing
<b>Tank 4 Equipment</b>		
Equipment Type	Permit Equipment	Action
Piping	Not Installed STP/Tanktop Sump	Removing
<b>Dispenser 1/2 Equipment</b>		
Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing
<b>Dispenser 5/6 Equipment</b>		
Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing
<b>Dispenser 7/8 Equipment</b>		
Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing