



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	2016791
Permit #:	00219-2026UPG
Request Rec'd:	02/23/2026
Approval Date:	02/25/2026 DS
Permit Expires:	08/25/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Graham C-Stores Co. 39109 N. US Hwy 41 Wadsworth, IL 60083 Lake County Contact: John Graham 847/223-3710	FACILITY - name and address where tanks are located: Sugar Grove #206 375 N. Sugar Grove Pkwy Sugar Grove, IL 60554 Kane County 14-16-401-004 Contact: Wendy Gustafson 847/223-3710Ext.15
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	20,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flexible Double Wall NUPI Smartflex	Replacing - Piping - Flexible Double Wall NUPI Smartflex
Piping	Single Wall Transition Sump	Removing
↳ Leak Detection - Piping	Sump Sensor	Removing

Dispensers on the Permit

Dispenser	Action
21/22	Removing
21S	Removing
21	New
21S / 22	New
22S	Removing
22S / 23	New
23S	New

Dispenser 21/22 Equipment

Equipment Type	Permit Equipment	Action
----------------	------------------	--------

Dispenser 21S Equipment

Equipment Type	Permit Equipment	Action
----------------	------------------	--------

Dispenser 21 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

Dispenser 21S / 22 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

Dispenser 22S Equipment

Equipment Type	Permit Equipment	Action
----------------	------------------	--------

Dispenser 22S / 23 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

Dispenser 23S Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

Summary of Work

Removing the existing DSL dispenser #21S, #22 & #22S along with the existing SW dispenser sumps & liquid sensors for those dispensers. Removing the existing transition sump as well. Revising the existing DW Nupi Smartflex DSL piping to those dispensers to facilitate the installation of (4) new SW Nupi Smartflex dispenser sumps as shown on drawing. Installing new Single Side DSL dispenser at #21, Master / Satellite dispensers at #21S/22 & #22S/23 and Satellite dispenser at #23S. Installing Veeder Root position sensitive liquid sensors at each new SSW dispenser sump with positive shutdown. The existing canopy is to be extended to cover the new dispenser islands.

Special Contingencies

NOTES: Dispensers must be at least 10' from all buildings and property lines. A removal permit must be obtained for the piping. If there are not currently existing sensors at the STP sumps with positive shut down, they must be installed as the piping being installed is over 20'.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Performance Tank, Inc. 730 Creel Drive Wood Dale, IL 60191	Contact Person: Tim Berg Phone: 847/612-6551 Email: tberg@perftank.com Contractor License # IL881 Exp. 12/8/2026

Sincerely,



Daniel Starks