



**City of Chicago**  
**Department of Public Health**  
 333 South State Street, Room 200  
 Chicago, IL 60604  
 312/745-3162  
 www.sfm.illinois.gov  
 SFM.DPCS@illinois.gov

<b>FOR OFFICE USE ONLY</b>	
Facility #:	2047983
Permit #:	00233-2026ABN
Request Rec'd:	02/27/2026
Approval Date:	03/02/2026 SK
Permit Expires:	09/02/2026

**Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>OWNER OF TANKS</b>          - Corporation, partnership, or other business entity:          Franciscan Outreach          1101 W. Adams Street          Chicago, IL 60607          Contact: Robret Simpson 312/748-5730</p>	<p><b>FACILITY</b>          - name and address where tanks are located:          Franciscan Outreach          2715 W. Harrison Street          Chicago, IL 60612          Cook County          16-13-400-022-0000          Contact: Robret Simpson 312/748-5730</p>
---	---

**Tanks on the Permit**

\* A combination of inert fill material is not allowed. The listed inert fill material is only allowed to fill the abandoned tank.

Tank #	Capacity	Product	Fill Material *
1	3,000	Heating Oil	Inert material mixed with portland cement

**Explanation of Waiver for Abandonment**

Abandonment in place of one 3,000 gallon heating oil tank in basement, due to very difficult access from above. A small hole was cut in the concrete floor to access the basement and collect information about the tank, but it is not directly above the tank. The concrete floor above the tank is not structurally sound.

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
RW Collins Company 7225 West 66th Street Chicago, IL 60638	Contact Person: Lisa Kruse Phone: 779/301-5966 Email: slucero@rwcollins.com Contractor License # IL772 Exp. 2/9/2028

Sincerely,

Sean Keane