



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	3009305
Permit #:	00234-2026UPG
Request Rec'd:	02/27/2026
Approval Date:	03/02/2026 DS
Permit Expires:	09/02/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Sherpa Properties, LLC 608 E. Jackson Street Macomb, IL 61455 (None) County Contact: Prabin Gautam 720/278-5912	FACILITY - name and address where tanks are located: Sherpa Stop 608 E. Jackson Street Macomb, IL 61455 McDonough County 11-200-314-00 Contact: Prabin Gautam 720/278-5912
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Diesel Fuel	8,000	Currently in use	Federal
5	Gasoline - Regular	10,000	Currently in use	Federal
6	Gasoline - Premium	10,000	Currently in use	Federal

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve OPW 53

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve

Summary of Work

Removing the Ball Float Vent Valves and replacing them with EBW Dual Pont Overfill Valves.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Pipeco, Inc. 610 29th Street Bettendorf, IA 52722	Contact Person: Robert Schafer Phone: 563/344-0700 Email: rob@pipecoinc.com Contractor License # IL2034 Exp. 9/28/2026

Sincerely,

Daniel J. Starks

Daniel Starks