



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**

1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	3012392
Permit #:	00239-2026ABN
Request Rec'd:	03/04/2026
Approval Date:	03/04/2026 DS
Permit Expires:	09/04/2026

Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

<p>OWNER OF TANKS - Corporation, partnership, or other business entity: OSF Healthcare System 1400 W. Park Street Urbana, IL 61801 Champaign County Contact: Eric Johnson 815/973-6966</p>	<p>FACILITY - name and address where tanks are located: OSF Healthcare System 695 N Kellogg St Galesburg, IL 61401 Knox County 99-10-281-023 Contact: Seth LeMay 309/345-4500</p>
---	--

Tanks on the Permit

* A combination of inert fill material is not allowed. The listed inert fill material is only allowed to fill the abandoned tank.

Tank #	Capacity	Product	Fill Material *
3	10,000	Diesel Fuel	Inert material mixed with portland cement

Explanation of Waiver for Abandonment

Tank is located within 4 feet from a buildings foundation. Abandon the piping as well, It is 4 feet, we will remove inside and cap with hydraulic cement

Location of Tanks Being Abandoned

Tank is located within 4 feet from a buildings foundation. Abandon the piping as well, It is 4 feet, we will remove inside and cap with hydraulic cement

Location of Piping Being Abandoned

Tank is located within 4 feet from a buildings foundation. Abandon the piping as well, It is 4 feet, we will remove inside and cap with hydraulic cement

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>Illinois Oil Marketing Equipment, Inc. 850 Brenkman Drive Pekin, IL 61554</p>	<p>Contact Person: Bryan Estes Phone: 309/202-0792 Email: amannino@iome.com Contractor License # IL1293 Exp. 2/4/2028</p>

Sincerely,

Daniel Starks